



MELCOR application to AP1000 SBO Simulation

Yaodong CHEN Tengfei LV Min LIAO

Div. of Advanced Nuclear System Research
State Nuclear Power Research Institute

2013. 05. 02



STATE NUCLEAR POWER TECHNOLOGY CORP.


OUTLINE

- **AP1000 overview**
- **MELCOR modeling of the plant**
- **Comparison of 2 SBO cases simulation results**
- **main finding and insight**
- **Future work**




Plant overview: Reactor system


- 157x14' 17x17 FAs
- No core lower plate
- 2 hot legs/ 4 cold legs
- No penetration in LH
- Canned type MCP, no risk of shaft seal leakage
- No intermediate section



- Steel containment vessel is part of passive safety system.
- PCS transfers heat from the shell to the environment.
- Water from Passive Containment Cooling Water Storage Tank (PCCWST) wets outer shell for > 72 hours.
- Natural convection air flow through containment annulus provides additional cooling.



Plant overview: PXS



Major components:
CMTs
Accumulators
IRWST
PRHRHX
Containment sump
Depressurization
(ADS) valves



- PRHR remove decay heat in event of loss of SG function, transferring heat to IRWST
- CMTs provide coolant at full system pressure to downcomer through DVI line.
- ADS 1~3 actuates in order when CMT level decreases below 67.5%.
- Two accumulators provide coolant at high flow rates when RCS < 700 psia.
- IRWST supplies borated water to RCS once sufficiently depressurized.
- ADS 4 initiates with CMT Low-2 level (20%) + Low RCS pressure (1200 psig)




Main control signal of safety system

Signal group	A	B	C	D	E
SCRAM(1)	PZR high pressure 2460 psia	PZR level HI-3 76% range	Primary flow low 87% of nominal flow	RCP low speed 90% of nominal speed	CMT injection
SCRAM(2)	SG level Low-1 95000lbm	ESF activated	ADS onset	PZR low-1 pressure 1800 psia	
MCP trip	“S” signal	SG-NR HI-2 100% range	Tavg Low-2 542 F		
“S”signal	Pzr_pressure low2 1700 psia	Steam pressur low 535 psia	Tcold Low 500 F	Pcont Hi-2 8 psig	
ADS1~3 trigger	CMT low-1 67.5% vol	Hot leg lev low- 2 0.072 m			
CMT injection	PZR level Low-2 7% range	“S”signal	ADS1~3 onset		
PRHR on	SG-NR Low+ startup feed failure	SG-WR Low 55000lbm	ADS1~3 onset	CMT injection	PZR level Hi-3 76% range
Turbine trip	SG-NR HI-2 100% range	“S” signal	scram		
MFW isolation	SG-NR HI-2 100% range	“S” signal	Tavg Low-1 542F		
ADS4 trigger	CMT low-2(20% vol) + Prcs<8.27 Mpa				
IRWST injection	ADS4 onset	Hotleg lev low2			




Equipment/ system	Medium/ str. Mass (ton)	Initial temp. (F)	Nominal pressure (MPa)	Water volume (m3)	Gas volume (m3)	Height (m)	Internal diameter (m)
Reactor							
core	/	2700*	15.5	/	/	4.267	1.59
cladding	/	650*	15.5	/	/	/	0.00836
RPV	72.55	301	2292/15.8	3510/99.4	0	12.2	4.04
RCS	199.4	301	2250/15.5	9620/273	1100/31.2	/	/
PZR	约15	345	2250/15.5	1000/28.3	1100/31.2	12.77	2.54
SG	84	271	814/5.61	148/5226	103/3637	19	4.19
PXS							
PRHR	2.88	49	15.5	1.55	0	11.55	0.01575
CMT	70.8	49	17.1	70.8	0	5.78	4.25
ACCU	39.6	49	4.9	39.6	17.1	7.5	4.76
CONT	/	49	0.1	/	58000	65.5	39.6
PCCWST	2592	49	0.1	2592	/	/	/
IRWST	2070	49	0.1	2070	238.1	9.69	/


MELCOR modeling of AP1000



COR module





Nodalization of primary&secondary and PXS system



Detailed PCS nodalization scheme



Configuration:
122 CVs
316 FLs
257 HSs




Plant Steady State Initialization



此处看到的是页眉幻灯片标题




Primary coolant flow rate



Primary&secondary pressure

Secondary steam flow rate




Core inlet&outlet temperature

Main assumptions:


- The reactor initially operated at full power
- All PXS and PCS system could work
except the ERVC measure considered failed
- Cooled water droplet draining down along
the containment shell inside wall will not
return to IRWST directly
- the containment shell surface area is down
scaled to account for partial coverage of water
film on the outer surface
- 2 cases are simulated
 - 1) PRHR started with 1 min delay after SG low
level signal true
 - 2) PRHR started immediately after reactor
scram






Comparison of PXS flow rate






Comparison of primary pressure trend





Comparison of water level in PXS tank and RCS






Abnormal ADS1 discharge flow


Comparison of RCS water inventory and discharge mass






Primary side&containment pressure V.S. heat removal trend(case1)






containment pressure trend





Water film thickness along the containment shell outside(case2)





Water film temperature along the containment shell outside(case2)



Main events of SBO Progression within 72 hrs

Sequences	timing (s/hr)			
	case1		case2	
	second	hour	second	hour
SBO initiated	0		0	
Reactor scram	2		2	
SG narrow range water level low	25		25	
Steam line stop valve closed	62		62	
PRHR line open	85		25	
primary low-2 true T-averagee	274		120	
CMT line started circulation	11711	3.3	260	
Pressurizer low-2 pressure	13380	3.7	88538	24.6
PCS started by containment high pressure	20066	5.6	14448	4.0
PRHR tubes uncovered	158000	43.9	151500	42.1
CMT level low-1, ADS1~3 triggered	222400	61.8	220620	61.3
Hotleg low level true, IRWST injection signal activated	222573	61.8	220757	61.3
ADS4 triggered	222573	61.8	220757	61.3
ACCU started injection	n/a	n/a	220787	61.3
Core exit temperature exceeded 1200 F	n/a	n/a	228605	63.5
Cavity –flooding activated	n/a	n/a	228605	63.5
PCCWST exhausted	n/a	n/a	273649	76.0
Calculation terminated	222600	61.8	290000	80.6



Main findings and insights

- Under LOOP and SBO accident condition, to avoid PRHR reverse flow, the PRHR Line should be opened as soon as the reactor scram. To study such complex phenomena, more detailed PRHR thermal-hydraulic nodalization scheme is needed. Earlier start of CMT will counter-act the cooling efficiency of PRHR.
- SBO lasted up to 72 hrs for AP1000, will not result in severe core degradation, As long as decay heat could be transferred from coolant to PRHR and IRWST, And then removed by PCS in a well coupled way, as demonstrated in the simulation.
- MELCOR seems to be overestimating the film thickness draining down from Dome top.
- In the phase of ADS discharge simulation, 2 version of MELCOR 186 generated quite big difference, the old version seems to have predicted more reasonable ADS flow rate.




Planned future work

- Severe accident simulation of long-term SBO extended to 1 week, as well as SA scenario from other extreme external events
- Validation of HSFT model against data from SNPTC containment validation test
- Detailed CVs and FLs for ERVC simulation will be added to current input deck, to study the effectiveness of IVR measures
- Transformation of current input model to larger passive NPP.
- Study on alternate SA mitigation measures for AP1000.
- Validation and improvement of current AP1000 SAMG






谢谢观赏
Thank you



Comparison of water level of PZR V.S. discharge rate of ADS 1





Comparison of CMT&PRHR&cold leg flow

