



MELCOR Modelling and Experience at NRG

Fabio Alcaro



NRG

17/03/2015

Outline

- Introduction
 - MELCOR use @ NRG
- Fukushima-Daiichi Unit-4 SFP
 - BWR vs SFP-BWR Models
 - Analysis of the Results
- SMR Steam Generator
 - TH modelling
 - CHF condition calculation
- Zircaloy Oxidation Model
- Conclusions

Introduction

Uses of MELCOR @ NRG:

❑ Post-Fukushima SFP analyses

- Spent Fuel Pool analyses in MELCOR (and other codes) in order to assess the coolability after a SFP LOCA scenario

❑ Severe accident analysis for KERENA

- (Part of) PSA Level 2 analysis
- Safety analyses for shutdown and power scenarios

❑ HFR calculations for license renewal

- Severe accident analyses
- PSA Level 2 analysis

❑ Severe accident analyses for the KCB power plant

- Safety analysis calculations

❑ KCB power plant desktop simulator

- Development of an interactive simulator of the Borssele NPP
- Dutch regulator personnel training


❑ GKN Dodewaard Power Plant

- PSA Level 2 analysis
- Direct containment heating analysis (comparison of MELCOR vs CONTAIN)

Introduction

Desktop simulator

- ❑ TH codes: MELCOR, RELAP, MAAP and SPECTRA (NRG code)
- ❑ Visor: NRG visualization software compatible with the most widespread TH codes



Window control

Plant mimic screen

Window information



Plant control and display board

ECCN = N

The screenshot shows the Visor v1.0.6 kcb.sim software interface. The main window displays a detailed plant mimic screen for the KCB - Primary System. The interface includes a top toolbar for window control, a main display area for the plant schematic, and a bottom control panel with various control buttons. The control panel includes sections for Pump control, RWST control, Feed water control, AUX FW control, Bump rec. control, Steam line control, Containment spray control, Valve control, Filter control, and SCRAM control. The status bar at the bottom shows window information (0.00, 715,680, 0.047, 512) and ECCN = N.

Fukushima SFP4

- ❑ SFP boil-off scenario with roof explosion (no water refilling)
- ❑ Low SFP initial water level (for speed-up purposes only)
- ❑ Model of the plant: SFP, refueling bay and environment
- ❑ CORE: 3 rings × 11 axial levels (6 for active fuel)
- ❑ Comparison between BWR and SFP-BWR reactor type (MELCOR 2.1)



Fukushima SFP4

❑ Rack component model:

- SFP-BWR: new component type 'rack' (mass in COR_KRK, surface in COR_RSA cards)
- BWR: generic NS SUPPORT component

❑ Different treatment of the loads on the structures (other differences?)

SFP-BWR					BWR				
EDIT OF NS AND SS SUPPORT AND FAILURE OPTIONS					EDIT OF NS AND SS SUPPORT AND FAILURE OPTIONS				
IA **** IR =	1	2	3	4	IA **** IR =	1	2	3	4
11 NS SUPPORT	FIXED	FIXED	FIXED	---	11 NS SUPPORT	BELOW	BELOW	BELOW	---
METAL	STEEL	STEEL	STEEL		METAL	STEEL	STEEL	STEEL	
DRMIN(M)	1.00E-04	1.00E-04	1.00E-04		DRMIN(M)	1.00E-04	1.00E-04	1.00E-04	
TMAX (K)	1700.00	1700.00	1700.00		TMAX (K)	1700.00	1700.00	1700.00	
10 NS SUPPORT	FIXED	FIXED	FIXED	---	10 NS SUPPORT	BELOW	BELOW	BELOW	---
METAL	STEEL	STEEL	STEEL		METAL	STEEL	STEEL	STEEL	
DRMIN(M)	1.00E-04	1.00E-04	1.00E-04		DRMIN(M)	1.00E-04	1.00E-04	1.00E-04	
TMAX (K)	1700.00	1700.00	1700.00		TMAX (K)	1700.00	1700.00	1700.00	
9 NS SUPPORT	FIXED	FIXED	FIXED	---	9 NS SUPPORT	BELOW	BELOW	BELOW	---
(etc.)					(etc.)				
EDIT OF CORE COMPONENT MASSES (KG)					EDIT OF CORE COMPONENT MASSES (KG)				
(..)					(..)				
*** LOAD (kg) CARRIED BY SUP-STR = 1.5696E+05					*** LOAD (kg) CARRIED BY SUP-STR = 1.8738E+05				
*** STRESS IN SUP-STR = 1.2647E+07					*** STRESS IN SUP-STR = 1.5098E+07				



Fukushima SFP4

Sequence of events of the accident scenario

Event	SFP-BWR	BWR
Gap release in rod group 1	648,300 s	654,200 s
Gap release in rod group 2	711,100 s	717,500 s
Core support structure has failed in cell ia= 2 ir= 3	722,400 s	
	failure was by over-temperature	
Core support structure has failed in cell ia= 2 ir= 1	843,900 s	773,700 s
	failure was by creep rupture	failure was by yielding
The lower head in segment 1 of ring 1 has failed from thru-wall yielding	843,400 s	
Beginning of debris ejection to cavity	843,400 s	
Core support structure has failed in cell ia= 2 ir= 2	855,700 s	
	failure was by creep rupture	
The lower head in segment 2 of ring 2 has failed from thru-wall yielding	855,700 s	
The lower head in segment 3 of ring 3 has failed from thru-wall yielding	855,700 s	
End of calculation	1,000,000 s	1,000,000 s

Fukushima SFP4

- ❑ The two models evolve similarly up to the rack base plate failure
- ❑ Rack base plate failure:
 - SFP-BWR: over-temperature + creep rupture
 - BWR: yielding
- ❑ Relocation of core material determines the base plate failure (highly variable process)
- ❑ SFP-BWR:
 - Failure of support plate in ring 3! (no core material above)
 - Radial relocation of core debris (is it meaningful for SFP application?)
 - Disable radial relocation by COR_TST card: code crash



Fukushima SFP4

Ring 1:

❑ Top of the fuel

- Fuel temperature peaks are caused by exothermic reaction of Zr and steam

❑ Bottom of the fuel

- Failure of the ring 1 support plate occurs at different time in the two models



Ring 2:

❑ Top of the fuel

- Fuel temperature is lower in the BWR-type model due to relocation of the cladding
- Fuel temperature in lower cells where cladding is still present is over 2000 K

❑ Bottom of the fuel

- Different behaviour because in the BWR-type model the support plate in ring 2 does not fail





Fukushima SFP4

□ Rack model:

- BWR: standard NS non-supporting structure
- SFP-BWR: dedicated rack component

□ Rack temperature evolution is surprisingly similar

- It seems that there is no particular differences in the COR model between the rack component and the standard NS structure




Fukushima SFP4

- ❑ **MELCOR has been used to simulate a severe accident evolution of the Fukushima Daiichi Unit-4 spent fuel pool**
- ❑ **SFP applications of MELCOR lack of full validation (SNL analysis on Fukushima SFP4 only covers the boil-off phase)**
- ❑ **The new MELCOR 2.1 reactor types SFP-BWR and SFP-PWR includes a few enhancements towards SFP modelling application:**
 - The new rack component is not considered in the load calculation of the support plate, which is consistent for SFP applications
 - There are not evidences that the rack component and the standard NS structures are treated differently in the COR package
- ❑ **The SFP-BWR and SFP-PWR reactor types require the SFP to be modelled as a reactor core:**
 - The radial ring model is not generally adequate for SFP application (generally the FAs are arranged in a checkerboard pattern alternating recently unloaded FAs with very old ones, for better coolability and criticality purposes)


SMR Steam Generator

- ❑ **Westinghouse SMR is an integral PWR system**
- ❑ **The steam production is a two-stage process:**
 - The primary coolant heat is removed in a tube-shell HX (straight tubes) inside the RPV
 - The steam is separated from the secondary two-phase mixture in a dedicated component
- ❑ **The SMR SG MELCOR model comes automatically from the SPECTRA code**
 - HX power: 800 MW
 - 9188 tubes, heated length ~ 6.1 m
 - The nodalization consists of 10 uniform axial nodes for the CVs (both tubes and shell) and HSs




SMR Steam Generator

- ❑ Post-CHF regime in the upper part of SG!
- ❑ Heat flux definition: $q_{atms} = \frac{Q_{atms}}{A_{atms}}$, $q_{pool} = \frac{Q_{pool}}{A_{pool}}$
- ❑ MELCOR result, node 165:
 - $q = 3.8 \text{ MW/m}^2$ (close to CHF)
 - $Q = 120 \text{ MW}$
 - $Q/A = 0.37 \text{ MW/m}^2$
- ❑ q definition appropriate for stratified flow
- ❑ Bubbly flow (~90% void) → overestimation of heat flux by about a factor of 10
- ❑ Problem can be partly remedied by changing the void fraction limit (sensitivity coefficient SC 4407, item 11):
 - default: $\alpha_{MAX} = 0.40$
 - changed to: $\alpha_{MAX} = 0.95$
- ❑ New results: no CHF.
- ❑ However, heat flux is still overestimated, by about factor of 2. Node 168:
 - $q = 0.73 \text{ MW/m}^2$ (close to CHF)
 - $Q/A = 0.36 \text{ MW/m}^2$




SMR Steam Generator

- Sensitivity coefficient SC 4407 item 11: default $\alpha_{MAX} = 0.40$



SMR Steam Generator

- Sensitivity coefficient SC 4407 item 11: modified $\alpha_{MAX} = 0.95$



SMR Steam Generator

□ Summary:

Node 165	MELCOR	MELCOR	RELAP	SPECTRA	
	$\alpha_{MAX} = 0.40$	$\alpha_{MAX} = 0.95$			
q (code output)	3.8	0.47	0.30	0.25	MW/m ²
Q/A (hand-calc.)	0.39	0.25	0.30	0.25	MW/m ²
Node 168	MELCOR	MELCOR	RELAP	SPECTRA	
	$\alpha_{MAX} = 0.40$	$\alpha_{MAX} = 0.95$			
q (code output)	CHF	0.73	0.34	0.35	MW/m ²
Q/A (hand-calc.)	~0	0.36	0.34	0.35	MW/m ²

□ Conclusion:

- In bubbly flow regime MELCOR overestimates heat flux
 - ✓ by ~10 for default α_{MAX} ,
 - ✓ by ~2 for $\alpha_{MAX}=0.95$,
 - ✓ no effect of α_{MAX} above 0.95.
- Effectively MELCOR underestimates CHF by the above mentioned ratios.
- This conclusion was reached with MELCOR 1.8.6.
Input converted to MELCOR 2.x → approximately the same results obtained with MELCOR 2.1.5540.

PWR SG MELCOR Model



- ❑ Results of 1300 MW_{th} PWR, KCB, MELCOR 2.1
 - Secondary side modeled by a single volume, CV-300
- ❑ Summary
 - No overestimation of heat flux.
- ❑ Conclusion
 - No effect in typical PWR SG geometry and modeling approach. Seems to be SMR-specific.
 - Is dividing secondary side of SG into a number of nodes (Control Volumes) a good idea?

Node 214
 $q(\text{POOL}) = 1.8\text{E}+005 \text{ W/m}^2$
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$
 $Q(\text{POOL}) = 5.8\text{E}+007 \text{ W}$
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$
 $Q(\text{POOL})/A = 1.8\text{E}+005 \text{ W/m}^2$
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

Node 221
 $q(\text{POOL}) = 1.5\text{E}+005 \text{ W/m}^2$
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$
 $Q(\text{POOL}) = 4.7\text{E}+007 \text{ W}$
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$
 $Q(\text{POOL})/A = 1.5\text{E}+005 \text{ W/m}^2$
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

Node 211
 $q(\text{POOL}) = 3.0\text{E}+005 \text{ W/m}^2$
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$
 $Q(\text{POOL}) = 6.7\text{E}+007 \text{ W}$
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$
 $Q(\text{POOL})/A = 2.9\text{E}+005 \text{ W/m}^2$
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

Node 224
 $q(\text{POOL}) = 9.8\text{E}+004 \text{ W/m}^2$
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$
 $Q(\text{POOL}) = 2.2\text{E}+007 \text{ W}$
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$
 $Q(\text{POOL})/A = 9.7\text{E}+004 \text{ W/m}^2$
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$



Zircaloy Oxidation Model

MELCOR model:

$$\log_{10} \tau = 42.038 - 12.528 \cdot \log_{10} T$$

Life function (T ≠ const):

$$LF = \int_0^t \frac{\vartheta}{\tau} d\vartheta = 1$$


$$t = \sqrt{2\tau}, \quad T = \text{const}$$

- LF is dimensional [s] (?)
- A test calculation (T=963 K) results in $t \approx 40,000$ s (in agreement with the Figure), while from the formula results $t \approx 283$ s

Modification of documentation:

$$LF = \int_0^t \frac{d\vartheta}{\tau} = 1$$

$$t = \tau, \quad T = \text{const}$$




R. Gauntt et al., Fukushima Daiichi Accident Study, SAND2012-6173

Zircaloy Oxidation Model

MELCOR 2.1 breakaway option (COR_OXB):

- By default the code adopts the pre-breakaway model (red line in the plot) without rising warnings, which is non-conservative for safety assessment
- MELCOR 1.8.6 uses Powers model (NUREG/CR-0649) by default for oxidation, which has a different behaviour wrt version 2.1)
- It is envisaged to adopt post-breakaway model by default (more consistent with code version 1.8.6)



Conclusions

Troubles and Issues

❑ Fukushima SFP4:

- SFP-BWR reactor type: radial core debris relocation option failure (Word 10 of COR_TST card set to value ISPR=3, disable the two radial relocation models)

❑ SMR Steam Generator:

- SG secondary side: fine CV nodalization can lead to CHF condition encountered in high void fraction volumes when high heat flux is involved

❑ Oxidation Model:

- Misdescription of the life function for time to breakaway in MELCOR 2.1 documentation
- Different default behaviour for the treatment of post-breakaway oxidation model with respect to the previous MELCOR 1.8.6

Summary

❑ Wide range of applications of MELCOR

❑ Many years of user experience: code versions from 1.8.2, 1.8.3, 1.8.4, 1.8.6 (mostly used in the past) to recent 2.x applications

Thank you for your attention!
Questions?

