



AREVA

forward-looking energy

AREVA's Current MELCOR Activities in Germany

Micha Loeffler, Matthias Braun

AREVA GmbH

Brussels, 17th – 18th March 2015



- ▶ **Simplified BWR Mark II containment model for MCCI with MELCOR 1.8.6**
 - ◆ **Containment model and purpose**
 - ◆ **Modeling of a core with the CAV package**
 - ◆ **Relocation between cavities**
 - ◆ **Example results**

- ▶ **AREVA's first trials with MELCOR 2.1**
 - ◆ **First experience**
 - ◆ **Challenges**

- ▶ **Visualization of PWR integral model results for SAMG training purposes**
(Lejla Musanovic → tomorrow)

Chapter 1

Mark II Containment Model


BWR Mark II – Containment Model Objective

- ▶ **Prediction of the overall accident progression**
 - ◆ Grace periods till and after RPV failure
 - ◆ Relocalization of molten corium within the containment
- ▶ **Identification of endangerments of the containment**
 - ◆ Temperature loads
 - ◆ Static & transient pressure loads
 - ◆ Impairing of building stability
- ▶ **Impact of accident mitigation measures**
 - ◆ Filtered venting operation


“

Goal of the study is the examination of possibilities for back-fitting a core catcher in a Mark II containment

”




BWR Mark II – Containment Threats



- (1) High-pressure RPV failure
→ MELCOR of limited usability
- (2) Compression of H₂ in wet-well after RPV failure
- (3) Steam explosion in control rod drive room
→ MELCOR of limited usability
- (4) Overheating of containment / penetrations
- (5) Radial penetration of pedestal
OR axial failure of floor
- (6) Pressure surge due to melt quenching
in inner wet-well
- (7) Steam explosion in inner or outer wet-well
→ MELCOR of limited usability
- (8) Basemat erosion & undercutting of pedestal

BWR Mark II – MELCOR Model



► Dry-well

- ◆ Splitting of DW to enable air/steam convection
- ◆ Necessary to gain realistic temperatures at penetrations / closure head

► Wet-well


- ◆ Horizontal cut within pool
- ◆ Allows for hot water layer on top pressure suppression pool by steam condensation
- ◆ Top water layer determines the pressure buildup in the containment

► Other structures

- ◆ 1 CV for 97 pressure suppression tubes
- ◆ 1 FL for the vacuum breakers
- ◆ A lot of heat structures

► No heat losses from containment


BWR Mark II – Corium Relocation Paths



- ▶ **CAV1 – Intact core**
- ▶ **CAV2 – Corium in RPV lower head**
- ▶ **CAV3 – Corium stuck on control rod drives**
 - ◆ ~ about 10^{-2} m thickness on 10 rods
- ▶ **CAV4 – Control rod drive (CRD) room**
 - ◆ Mass of 10 drives added to melt
 - ◆ Mass of control rod changing machine added
- ▶ **CAV5+6+7 – Sumps within the CRD room**
 - ◆ Oil sump, Equipment sump, & Drain sump
 - ◆ Sequential filling of sumps if CAV4 layer thickness > 10 cm / > 15 cm / > 20 cm
- ▶ **CAV8 – Outer wet-well floor**
 - ◆ After radial penetration of RPV pedestal
- ▶ **CAV9 – Inner wet-well floor**
 - ◆ After axial penetration of CRD room floor

BWR Mark II – Model Simplifications

- ▶ **No usage of RN or COR package**
 - ◆ Replacement of core by a special constructed CAV
- ▶ **Relocation of corium and RPV failure defined by CF**
 - ◆ CF-controlled overflow heights used to avoid unphysical (MELCOR-typical) instantaneous relocalization
- ▶ **Simplified modelling of the reactor coolant system**
 - ◆ Time independent CVs as sources/sinks for feed water and steam system
 - ◆ One safety relief valve
 - ◆ One CV per CAV
- ▶ **Limited modelling scope for safety systems**
 - ◆ Filtered containment venting system as one FL with TF mass flow vs. containment pressure
 - ◆ Fire protection system modelled as spray (SPR)
 - ◆ No safety injection (limitation to Fukushima Unit 1 – like scenarios)



BWR Mark II – CAV as COR Substitute (I/II)



► Cavity instead of core input:

CAV01C0 INERT

...

CAV01C1 ZRO2 1.0

* ZrO2 to prevent ablation

* Layer content

CAV0110 TEMP 550.

CAV0111 UO2 158.E3

CAV0112 FE 21.8E3

CAV0113 ZR 38.2E3

CAV0114 ZRO2 51.6E3

* no reactor poison possible

...

CAV01U2 EMISS.OX 0.01

* only very small emissivity as large surface area

CAV01U3 EMISS.MET 0.01

* of fuel rods shine on its self more than on

CAV01U4 EMISS.SUR 0.01

* other structures

* but: CAV02U2 EMISS.OX 0.8

BWR Mark II – CAV as COR Substitute (II/II)



► Hydrogen production during core destruction:

* Hydrogen addition

*-----

* If CAV1 reaches 1200°C, then add 1675 kg hydrogen at 1200°C with 1 kg/s

CF5109100	'CAV.1.Temp'	MAX	5	1.0	0.0
CF5109101	500.				
CF5109111	1.0	0.0	CAV-T.HMX.1		
CF5109112	1.0	0.0	CAV-T.HOX.1		
CF5109113	1.0	0.0	CAV-T.LMX.1		
CF5109114	1.0	0.0	CAV-T.LOX.1		
CF5109115	1.0	0.0	CAV-T.MET.1		

► Relocation from CAV 1 to CAV 2 at 1700 K in CAV 1 (melting SS structures):

CAV01RA	02	51012	* axial rupture, defined by CF-controlled rupture,
			* axial rupture & no height CF = full dump in CAV2



► Add mass in CAV4

* Initial layer content

*-----

* Assumption: 5% of control rods drop down

* Mass CRD changing machine [kg] 10.E3 * estimate

CAV0410 TEMP 333.15 * = 60+273.15

CAV0412 FE 13.0E3 * 10% of RPV internals below the core

► One cavity can only drain in up to **three** cavities

► Cavity CAV 5 + 6 drain into CAV7 (example):

* R_adial, A_xial, or by con_T_rol function

* | NOV = receiving CAV number

* | | NCFRUP = control function triggering rupture

* | | | NCFREL = height of rupture (optional for R & A)

* | | | |

CAV05RA 07 58028 58030 * axial rupture, defined by CF

CAV06RA 07 58029 58030

BWR Mark II Containment Model – CAV Package



- ▶ Quenching in CAV 8 + 9 after relocation from CAV 4 + 7 as conservative assumption for PCV loads

* spread on 40 m radius disk > 5000 m² to ensure coolability

* ZT - top edge height (in RG0)

* RAD - radius

* HIT - height of cylindrical cavity

* RADC - radius of corner

* RW - external radius

* HBB - bottom thickness

* NBOT - no

* NCORN


CAV08G2	3.760	40.	1.0	0.1	50.	10.	10	3
---------	-------	-----	-----	-----	-----	-----	----	---

- ▶ Reheating in wet-well not possible, because only 9 cavities allowed
- ▶ Molten corium is submerged with water if a pool exists in the connected CV
- ▶ Test with stratified corium: Increased radial ablation but “noisy” cavity shape

BWR Mark II – Predicted Cavity Shape


► Cavity shape (example)

- ◆ Shape generated by overlay of the three CAV of the three sumps (Excel)
- ◆ Assumption: enforced mixing of melt



BWR Mark II – Melt Masses and Positions

► Relocation between the cavities (example)





► Simple model

- ◆ Economic model generation
- ◆ Short project time (several weeks)
- ◆ Fast running model (2 CPU-hr per 24 hr problem time on standard Windows PC)

► Model sufficient to answer the following questions

- ◆ Accident grace periods (for SBO scenarios)
- ◆ Containment pressure build-up & pressure peaks
- ◆ Containment temperatures

► Should-knows of the CAV package

- ◆ One CAV can drain only in 3 other CAV (CAVxxRA, CAVxxRR, CAVxxRT)
- ◆ Only 9 cavities do work (even so 100 CAV can be defined)
- ◆ Corium is perfectly submerged with water as long as a pool exists in the connected CV (no height information transmitted between CAV and CVH)
- ◆ Stratified corium gives understandable but “noisy” cavity shape (raises doubts about model reliability)



The MELCOR code is very flexible and can easily be adapted to specific questions



Chapter 2

First Trials with MELCOR 2.1

First Trials with MELCOR 2.1 –Task and Challenges


► **Task:** Translation of input decks for different KWU PWRs for validation purpose to use MELCOR 2.1 in future (BWRs possibly later)

- ◆ The models comprise **25,000–29,000** lines in MELCOR 1.8.6 (without comments)
- ◆ Excessive in-code comments for quality assurance
- ◆ The input is divided into ~42 modular files
- ◆ **To learn more about the challenges of translation with SNAP, we have started with the latest model “C.N. Trillo”**



First Trials with MELCOR 2.1 – Approach

- ▶ Combining all files into a single one (required for unique names)
- ▶ Translation with SNAP
 - ◆ Minor changes especially for global parameters, MELGEN and MELCOR directives
- ▶ First trial to run the input
 - ➔ **crash** during building the restart file
- ▶ Splitting input into modules and reduction
 - ➔ **crash**
- ▶ Further reduction of the input:
 - only an RPV with time independent boundary volumes
 - ➔ **running, although it contains complex input files**



First Trials with MELCOR 2.1 – Crash 1

► Access violation

forrtl: severe (157): Program Exception - access violation

C:\Windows\system32\cmd.exe					
File exists. Reading...					
Read file. Getting Unique Identifier from system for comparison.					
Queried system unique ID. Comparing...					
Valid software license confirmed.					
Software access granted.					
MELGEN BASE CODE VERSION					
2.1 SEP-06-2014					
This is an official build.					
MELGEN 2.1.6342					
COMMAND-LINE ARGUMENTS:					
Opening user input file CNT1-20150115-MELCOR21.inp					
Input Pass1 : Block comments read <<< CF_FISSIONPOWER >>>					
Input Pass1 : Block comments skipped <<< EBSBETON >>>					
Input Pass1 : Block comments skipped <<< DEGASSINGCOREBARREL >>>					
Input Pass1 : Block comments skipped <<< IP_MTX-DEFAULT >>>					
Input Pass1 : Block comments skipped <<< CORE-MS >>>					
Input Pass1 : Block comments skipped <<< CORE-SS >>>					
Input Pass1 : Block comments skipped <<< CORE-KFU >>>					
Input Pass1 : Block comments skipped <<< CORE-KCL >>>					
Input Pass1 : Block comments skipped <<< CORE-KSS >>>					
Input Pass1 : Block comments skipped <<< CORE-KNS >>>					
Input Pass1 : Block comments skipped <<< CORE-KSH >>>					
Input Pass1 : Block comments skipped <<< CORE-KFM >>>					
Input Pass1 : Block comments skipped <<< CORE-PCT >>>					
Input Pass1 : Block comments skipped <<< CORE-SDR >>>					
Input Pass1 : Block comments skipped <<< CORE-SSA >>>					
Input Pass1 : Block comments skipped <<< CORE-LHN >>>					
forrtl: severe (157): Program Exception - access violation					
Image	PC	Routine	Line	Source	
Melgen_RL_LIC_634	00865E30	_TH2O_H2OEST_ip_T	439	h2oest_NSI.f90	
Melgen_RL_LIC_634	00865871	_TH2O_H2OEST@48	74	h2oest_NSI.f90	
Melgen_RL_LIC_634	00865329	_TH2O_H2OSAU@56	142	h2osat_NSI.f90	
Melgen_RL_LIC_634	00C5386E	_CVH_GENERATEDB_i	991	CVH_GenerateDB.f90	
Melgen_RL_LIC_634	00C47A93	_CVH_GENERATEDB@4	359	CVH_GenerateDB.f90	
Melgen_RL_LIC_634	0090FC5F	_GENERATEDB@4	44	GenerateDB.f90	
Melgen_RL_LIC_634	008A6554	_EXEC_MEGGDB@4	61	meggdb_NSI.f90	
Melgen_RL_LIC_634	00401365	_M_MELGENPROG_mp_	158	m_MelgenProg.f90	
Melgen_RL_LIC_634	0040102D	_MAIN__	7	Melgen_NSI.f90	
Melgen_RL_LIC_634	00B95013	Unknown	Unknown	Unknown	
Melgen_RL_LIC_634	005CE967	Unknown	Unknown	Unknown	
Melgen_RL_LIC_634	005CE83F	Unknown	Unknown	Unknown	
kernel32.dll	772D338A	Unknown	Unknown	Unknown	
ntdll.dll	77839F72	Unknown	Unknown	Unknown	
ntdll.dll	77839F45	Unknown	Unknown	Unknown	

First Trials with MELCOR 2.1 – Crash 2



I/O

forrtl: severe (256): unformatted I/O to unit open for
formatted transfers, unit 31, file
D:\0004_MELCOR_v21\MELCOR_21_CNT1_MODULS_20150217_RCS-
SHELL\R35.GOUT

```
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< HS-DEGASSING >>>
Input Pass1 : Block comments skipped <<< HS-RD >>>
Input Pass1 : Block comments skipped <<< FL-ULU >>>
Input Pass1 : Block comments skipped <<< FL-PMP >>>
Input Pass1 : Block comments skipped <<< FL-UTM >>>
Input Pass1 : Block comments skipped <<< RM1-DS-CONTAINMENT >>>
Input Pass1 : Block comments skipped <<< RM1-SET-CONTAINMENT >>>
Input Pass1 : Block comments skipped <<< RM2-FLT >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
Input Pass1 : Block comments read <<< SOU >>>
forrtl: severe (256): unformatted I/O to unit open for formatted t
31, file D:\0004_MELCOR_v21\MELCOR_21_CNT1_MODULS_20150217_RCS-SH
Image PC Routine Line Source
Melgen_RL_LIC_634 005C894A Unknown Unknown Unknown
Melgen_RL_LIC_634 00586650 Unknown Unknown Unknown
Melgen_RL_LIC_634 0058582A Unknown Unknown Unknown
Melgen_RL_LIC_634 0055F77B Unknown Unknown Unknown
Melgen_RL_LIC_634 008A9EB8 _ARGCF_CONNECTVAL 2737 ArgCF_Connect.f90
Melgen_RL_LIC_634 008E4F88 _ARGCF_CONNECTVAL 546 ArgCF_Connect.f90
Melgen_RL_LIC_634 008A9477 _ARGCF_CONNECTVAL 505 ArgCF_Connect.f90
Melgen_RL_LIC_634 008A71F0 _ARGCF_CONNECT@4 119 ArgCF_Connect.f90
Melgen_RL_LIC_634 008A9EB8 _ARGCF_CONNECTVAL 2737 ArgCF_Connect.f90
Melgen_RL_LIC_634 008E4F88 _ARGCF_CONNECTVAL 546 ArgCF_Connect.f90
Melgen_RL_LIC_634 008A9477 _ARGCF_CONNECTVAL 505 ArgCF_Connect.f90
Melgen_RL_LIC_634 008A71F0 _ARGCF_CONNECT@4 119 ArgCF_Connect.f90
Melgen_RL_LIC_634 00BE9D5B _CF_CFPS3@4 29 cfps3_NSI.f90
Melgen_RL_LIC_634 0090FFDD _PREPARETORUN@4 122 PrepareToRun.f90
Melgen_RL_LIC_634 008A69F2 _EXEC_MEGGDB@4 80 meggdb_NSI.f90
Melgen_RL_LIC_634 00401365 _M_MELGENPROG_mp_ 158 m_MelgenProg.f90
Melgen_RL_LIC_634 00B95013 Unknown Unknown Unknown
Melgen_RL_LIC_634 005CE967 Unknown Unknown Unknown
Melgen_RL_LIC_634 005CE83F Unknown Unknown Unknown
kernel32.dll 772D338A Unknown Unknown Unknown
ntdll.dll 77839F72 Unknown Unknown Unknown
ntdll.dll 77839F45 Unknown Unknown Unknown
D:\0004_MELCOR_v21\MELCOR_21_CNT1_MODULS_20150217_RCS-SHELL>pause
Drücken Sie eine beliebige Taste . . .
```

Image	PC	Routine	Line	Source
Melgen_RL_LIC_634	005C894A	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	00586650	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	0058582A	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	0055F77B	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	008A9EB8	_ARGCF_CONNECTVAL	2737	ArgCF_Connect.f90
Melgen_RL_LIC_634	008E4F88	_ARGCF_CONNECTVAL	546	ArgCF_Connect.f90
Melgen_RL_LIC_634	008A9477	_ARGCF_CONNECTVAL	505	ArgCF_Connect.f90
Melgen_RL_LIC_634	008A71F0	_ARGCF_CONNECT@4	119	ArgCF_Connect.f90
Melgen_RL_LIC_634	00BE9D5B	_CF_CFPS3@4	29	cfps3_NSI.f90
Melgen_RL_LIC_634	0090FFDD	_PREPARETORUN@4	122	PrepareToRun.f90
Melgen_RL_LIC_634	008A69F2	_EXEC_MEGGDB@4	80	meggdb_NSI.f90
Melgen_RL_LIC_634	00401365	_M_MELGENPROG_mp_	158	m_MelgenProg.f90
Melgen_RL_LIC_634	00B95013	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	005CE967	Unknown	Unknown	Unknown
Melgen_RL_LIC_634	005CE83F	Unknown	Unknown	Unknown
kernel32.dll	772D338A	Unknown	Unknown	Unknown
ntdll.dll	77839F72	Unknown	Unknown	Unknown
ntdll.dll	77839F45	Unknown	Unknown	Unknown



AREVA
forward-looking energy

First Trials with MELCOR 2.1 – Summary



- ▶ All users should have a Bugzilla account
 - ➔ At least for reading the discussions
- ▶ The translation with SNAP seems to be very **easy** but not without **issues**
- ▶ The splitting of the converted input into modules and re-adding the comments is very exhausting
- ▶ The collected input, e.g. for **HS_RD**, **FL_FLSH**, **FL_VLV**, **FL_VTM**, and **FL_PMP**, complicates the modularization of the input
- ▶ Searching for errors is difficult if these are not recognized by MELGEN

“

Translation is relatively easy, but
maybe it is better to start with
smaller input decks

”



“

Editor and Copyright [2015-03-17]: AREVA GmbH – Paul-Gossen-Straße 100 – 91052 Erlangen, Germany. It is prohibited to reproduce the present publication in its entirety or partially in whatever form without prior written consent. Legal action may be taken against any infringer and/or any person breaching the aforementioned prohibitions.

Subject to change without notice, errors excepted. Illustrations may differ from the original. The statements and information in this brochure are for advertising purposes only and do not constitute an offer of contract. They shall neither be construed as a guarantee of quality or durability, nor as warranties of merchantability or fitness for a particular purpose. These statements, even if they are future-orientated, are based on information that was available to us at the date of publication. Only the terms of individual contracts shall be authoritative for type, scope and characteristics of our products and services.

”

Thank you for your attention!

End of Presentation: AREVA's Current MELCOR Activities in Germany

Micha Loeffler, Matthias Braun

AREVA GmbH

Brussels, 17th – 18th March 2015