









### ÚJV Řež, a.s.

## **GFR modeling in Melcor 1.8.6** experience, troubles, solutions

Petr Vácha

petr.vacha@ujv.cz

7th EMUG, Brussels, March 17-18, 2015





## GFR ALLEGRO

- MELCOR model of ALLEGRO
- Troubles and (sometimes) solutions
- Results





### A concept of prototypic GENIV GFR

- Originally developed by CEA, continues in Central Europe
- Goal: to test GFR-related technology, qualify a new type of refractory fuel, demonstrate viability of the GFR concept

### Legal frame: Association "V4G4 Centre of Excellence"

- Registered in August 2013 in Slovakia
- VUJE (general. designer): Design & Safety (with ÚJV assistance)
- ÚJV Řež: R&D and exp. support (He technology, …)
- MTAEK Budapest: Fuel
- NCBJ Swierk: Materials

CEA plans to become associated member (observer to support V4G4)



# **GFR ALLEGRO - specifications**

#### • CEA ALLEGRO (2009) concept:

- Reactor unit size: 75 MWt
- Core power density: 100 MWt/m<sup>3</sup>
- Coolant: He
- Nominal pressure: 7 MPa
- Fuel forms: MOX pin-type (starting core)

**Ceramic pin-type (refractory core)** 


Core outlet temperature: 530°C (starting)

750°C (refractory)




# CEA ALLEGRO 2009 (75 MWt)






# CEA ALLEGRO 2009 (75 MWth)











# **ALLEGRO – global facility**





## **ALLEGRO - MOX Core**






# **ALLEGRO COR model**



 Core includes bypass – BWR model used

#### •BWR model puts NS to bypass -

NS modeled as cladding in regions with bypass





# **DHR system model**




### DHR system model

- Very complicated shape and flow path
- Blower and intermediate circuit pump on –OK
- SBO natural convection mode in both DHR exhanger and i.c.

### DHR blower model

- SBO no problem
- LOCA scenarios homologous model under developement





## **Unsolved issues**



#### MELCOR 1.8.6 calculations

- RN package off no problem
- RN package on calculations fail each time after the first "gap release" message by "math error", no output is written in the diagnostic files.


### MELCOR 2.1 calculations

 Numerical instabilities leading to crashes in case of natural convection mode in the DHR system during blackout. 1.8.6. has no problem using the same input.



### **Decay heat**






## **SBO results**



 main check valves close + DHR check valves do not open – worst possible scenario


•Result is total loss of cooling and core overheating – melting of cladding in less than 16 minutes






### **Blackout results**





### **Blackout results**









- Fast propagation cladding failure after only 16 minutes
- No fuel melting occurs until relocation to lower head lack of oxidic molten pool
- third ring remains almost untouched probably due to fast "dissapearance" of fuel from first two rings?
- Lot of steel remains in the core region does not participate in heat dissipation after relocation (internal core catcher? Liner?)







ALLEGRO is still in (pre)conceptual phase – lot of changes in design expected

- Modeling of GFR in MELCOR is complicated but possible
- Results of severe accident calculations will help to further develop the safety systems of ALLEGRO

