



# MELCOR Application to the Analysis of SMR

**Fabio Alcaro**

**EU DuC=N**

**6-7/04/2016**

**NRG**

# Outline

- Introduction
  - NRG Experience with MELCOR
- SMR Steam Generator
  - TH model
  - CHF condition calculation
- SMR Check Valves
  - Control Function definition
- Collapsed Water Level
  - Sensitivity on bubble rise velocity
- Conclusions

# Introduction

## Uses of MELCOR @ NRG:

### ❑ Post-Fukushima SFP analyses

- Spent Fuel Pool analyses in MELCOR (and other codes) in order to assess the coolability after a SFP LOCA scenario

### ❑ Severe accident analysis for KERENA

- (Part of) PSA Level 2 analysis
- Safety analyses for shutdown and power scenarios

### ❑ HFR calculations for license renewal

- Severe accident analyses
- PSA Level 2 analysis

### ❑ Severe accident analyses for the KCB power plant

- Safety analysis calculations

### ❑ KCB power plant desktop simulator

- Development of an interactive simulator of the Borssele NPP
- Dutch regulator personnel training


### ❑ GKN Dodewaard Power Plant

- PSA Level 2 analysis
- Direct containment heating analysis (comparison of MELCOR vs CONTAIN)

# Introduction

## Desktop simulator

- ❑ TH codes: MELCOR, RELAP, MAAP and SPECTRA (NRG code)
- ❑ Visor: NRG visualization software compatible with the most widespread TH and SA codes



Window control


Plant mimic screen

Window information

Plant control and display board

# Westinghouse SMR

- ❑ **Westinghouse SMR is an integral PWR nuclear system**
- ❑ **The Pressure Vessel and most of the passive safety system components are contained inside a Containment Vessel**
  - The Containment Vessel is immersed in a pool of cold water (OCP)
  - The atmosphere inside the Containment Vessel is highly depressurized under NC
- ❑ **The Passive Safety System (PXS) is made of:**
  - The In-Containment Pool (ICP);
  - Four Core Makeup Tanks (CMT), each containing a PRHR heat exchanger;
  - Two Sump Injection Tanks (SIT), connected to the ICP
  - A two-stage automatic depressurization system (ADS)
  - An Upper Internal Storage Tank (UIST)
  - An Out-Containment Pool (OCP) housing the CV




# SMR Steam Generator

## ❑ The MELCOR model of the SMR Steam Generator

- HX power: 800 MW
- Once-through tube-shell HX
- The TH nodalization consists of 10 uniform axial nodes for the CVs (both tubes and shell)
- The tubes wall is modelled with 10 heat structures with the same node geometry of the boundary CVs

## ❑ The steam production is a two-stage process:

- The primary coolant heat is removed in a tube-shell HX (straight tubes) inside the RPV
- The steam is separated from the secondary two-phase mixture in a dedicated component



# SMR Steam Generator

- ❑ Post-CHF regime in the upper part of SG!

$$q_{atms} = \frac{Q_{atms}}{A_{atms}}, \quad q_{pool} = \frac{Q_{pool}}{A_{pool}}$$

- ❑ Heat flux definition:
- ❑ MELCOR result, node 165:
  - $q = 3.8 \text{ MW/m}^2$  (close to CHF)
  - $Q = 120 \text{ MW}$
  - $Q/A = 0.37 \text{ MW/m}^2$
- ❑  $q$  definition appropriate for stratified flow
- ❑ Bubbly flow (~90% void) → overestimation of heat flux by about a factor of 10

WSMR, MELCOR, SG, Tubes											Time:	0.0 s
Q = -792.2 MW												
Primary side (inside tubes) CV-113/122				Tube wall SC-160/169		Secondary side (outside) CV-160/169						
JN-112   from CV-112 4406 kg/s   606 K 4.79 m/s   15.54 MPa						JN-169   to CV-155 752 kg/s   521 K 5.42 m/s   6.00 MPa						
V-gas, m/s	T-gas, K	h	T, K	h	T-gas, K	V-gas, m/s	V-liq, m/s	T-liq, K	X [-]	Q [kW/m <sup>2</sup> K]	X [-]	
(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)	(10)	(11)	(12)	
0.00	601	0.00	32.37	584	571	559	177.48	0.55	564	6.53	CV-169	
4.73	601	0.00	32.06	600	600	599	0.00	0.43	571	5.74	JN-168	
0.00	601	0.00	32.03	600	599	598	0.00	0.42	566	5.60	CV-168	
4.67	601	0.00	32.03	600	599	598	0.00	0.42	549	4.33	JN-167	
0.00	601	0.00	31.99	599	598	598	0.00	0.42	559	5.43	CV-167	
4.66	601	0.00	31.99	599	598	598	0.00	0.42	549	4.40	JN-166	
0.00	600	0.00	31.71	582	571	561	324.55	0.41	552	4.76	CV-166	
4.61	596	0.00	31.71	582	571	561	324.55	0.41	549	3.92	JN-165	
0.00	592	0.00	31.36	579	569	559	238.71	0.30	551	3.64	JN-164	
4.53	592	0.00	31.36	579	569	559	238.71	0.30	549	3.03	CV-165	
0.00	588	0.00	31.08	576	566	557	171.28	0.20	551	2.62	JN-163	
4.46	588	0.00	31.08	576	566	557	171.28	0.20	549	2.16	CV-163	
0.00	584	0.00	30.85	573	564	556	117.37	0.11	550	1.78	JN-162	
4.40	584	0.00	30.85	573	564	556	117.37	0.11	549	1.32	CV-162	
0.00	581	0.00	30.65	570	562	555	72.06	0.03	550	1.16	JN-161	
4.34	581	0.00	30.65	570	562	555	72.06	0.03	549	0.71	CV-161	
0.00	577	0.00	30.48	568	561	554	23.32	0.00	543	0.00	JN-160	
4.30	577	0.00	30.48	568	561	554	23.32	0.00	543	0.45	CV-160	

**Node 168**  
 $q(\text{POOL}) = 0.0\text{E}+000 \text{ W/m}^2$   
 $q(\text{ATMS}) = 2.5\text{E}+004 \text{ W/m}^2$   
 $Q(\text{POOL}) = 0.0\text{E}+000 \text{ W}$   
 $Q(\text{ATMS}) = 7.3\text{E}+006 \text{ W}$   
 $Q(\text{POOL})/A = 0.0\text{E}+000 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 2.3\text{E}+004 \text{ W/m}^2$

**Node 165**  
 $q(\text{POOL}) = 3.8\text{E}+006 \text{ W/m}^2$   
 $q(\text{ATMS}) = 7.2\text{E}+003 \text{ W/m}^2$   
 $Q(\text{POOL}) = 1.2\text{E}+008 \text{ W}$   
 $Q(\text{ATMS}) = 2.0\text{E}+006 \text{ W}$   
 $Q(\text{POOL})/A = 3.9\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 6.4\text{E}+003 \text{ W/m}^2$



# SMR Steam Generator

- ❑ Problem can be partly remedied by changing the void fraction limit (sensitivity coefficient SC 4407, item 11):

- default:  $\alpha_{MAX} = 0.40$
- changed to:  $\alpha_{MAX} = 0.95$

- ❑ New results: no CHF.

- ❑ However, heat flux is still overestimated, by about factor of 2. Node 168:

- $q = 0.73 \text{ MW/m}^2$  (close to CHF)
- $Q/A = 0.36 \text{ MW/m}^2$

WSMR, MELCOR, SG, Tubes											Time:	0.0 s	
Q = -793.5 MW													
Primary side (inside tubes) CV-113/122				Tube wall SC-160/169		Secondary side (outside) CV-160/169							
JN-112 from CV-112 4503 kg/s 4.68 m/s				to CV-112 597 K 15.53 MPa		JN-169 to CV-155 752 kg/s 6.68 m/s						521 K 6.00 MPa	
V-gas, m/s	T-gas, K	T-liq, K	X [-]	h kW/m <sup>2</sup> K	T, K (1) (2) (3)			h kW/m <sup>2</sup> K	X [-]	T-gas, K	V-gas, m/s	V-liq, m/s	
0.00	592	592	0.00	31.96	578	566	555	98.01	0.30	551	6.48	6.15	
4.64	592	592	0.00	31.96	578	566	555	98.01	0.30	551	6.48	6.15	
0.00	588	588	0.00	31.64	575	565	556	107.54	0.26	551	5.28	5.28	
4.56	588	588	0.00	31.64	575	565	556	107.54	0.26	551	5.28	5.08	
0.00	584	584	0.00	31.39	573	564	555	99.00	0.21	551	4.28	4.28	
4.50	584	584	0.00	31.39	573	564	555	99.00	0.21	551	4.28	4.09	
0.00	581	581	0.00	31.19	571	563	555	99.89	0.16	551	3.40	3.40	
4.44	581	581	0.00	31.19	571	563	555	99.89	0.16	551	3.40	3.21	
0.00	578	578	0.00	31.02	569	562	555	80.22	0.12	551	2.62	2.62	
4.40	578	578	0.00	31.02	569	562	555	80.22	0.12	551	2.62	2.44	
0.00	575	575	0.00	30.87	567	560	554	70.05	0.08	550	1.94	1.94	
4.36	575	575	0.00	30.87	567	560	554	70.05	0.08	550	1.94	1.75	
0.00	572	572	0.00	30.75	565	559	554	59.55	0.05	550	1.35	1.35	
4.32	572	572	0.00	30.75	565	559	554	59.55	0.05	550	1.35	1.14	
0.00	570	570	0.00	30.65	563	558	554	48.93	0.02	550	0.99	0.99	
4.29	570	570	0.00	30.65	563	558	554	48.93	0.02	550	0.99	0.65	
0.00	568	568	0.00	30.57	562	557	553	24.16	0.00	546	0.00	0.00	
4.27	568	568	0.00	30.57	562	557	553	24.16	0.00	546	0.00	0.46	
0.00	566	566	0.00	30.51	561	557	553	7.17	0.00	533	0.00	0.00	
4.24	566	566	0.00	30.51	561	557	553	7.17	0.00	533	0.00	0.45	

**Node 168**  
 $q(\text{POOL}) = 7.3\text{E}+005 \text{ W/m}^2$   
 $q(\text{ATMS}) = 4.0\text{E}+003 \text{ W/m}^2$   
 $Q(\text{POOL}) = 1.1\text{E}+008 \text{ W}$   
 $Q(\text{ATMS}) = 6.6\text{E}+005 \text{ W}$   
 $Q(\text{POOL})/A = 3.6\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 2.1\text{E}+003 \text{ W/m}^2$

**Node 165**  
 $q(\text{POOL}) = 4.7\text{E}+005 \text{ W/m}^2$   
 $q(\text{ATMS}) = 2.2\text{E}+003 \text{ W/m}^2$   
 $Q(\text{POOL}) = 7.9\text{E}+007 \text{ W}$   
 $Q(\text{ATMS}) = 3.4\text{E}+005 \text{ W}$   
 $Q(\text{POOL})/A = 2.5\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 1.1\text{E}+003 \text{ W/m}^2$



# SMR Steam Generator

## ❑ Comparison with other TH codes:

Node 165	MELCOR	MELCOR	RELAP	SPECTRA	
	$\alpha_{MAX} = 0.40$	$\alpha_{MAX} = 0.95$			
$q$ (code output)	3.8	0.47	0.30	0.25	MW/m <sup>2</sup>
Q/A (hand-calc.)	0.39	0.25	0.30	0.25	MW/m <sup>2</sup>
Node 168	MELCOR	MELCOR	RELAP	SPECTRA	
	$\alpha_{MAX} = 0.40$	$\alpha_{MAX} = 0.95$			
$q$ (code output)	CHF	0.73	0.34	0.35	MW/m <sup>2</sup>
Q/A (hand-calc.)	~0	0.36	0.34	0.35	MW/m <sup>2</sup>

## ❑ Conclusion:

- In bubbly flow regime MELCOR overestimates heat flux
  - ✓ by ~10 for default  $\alpha_{MAX}$ ,
  - ✓ by ~2 for  $\alpha_{MAX}=0.95$ ,
  - ✓ no effect of  $\alpha_{MAX}$  above 0.95.
- Effectively MELCOR underestimates CHF by the above mentioned ratios.
- This conclusion was reached with MELCOR 1.8.6.  
Input converted to MELCOR 2.x → approximately the same results obtained with MELCOR 2.1.5540.

# PWR SG MELCOR Model



- ❑ Results of 1300 MW<sub>th</sub> PWR, KCB, MELCOR 2.1
  - Secondary side modeled by a single volume, CV-300
- ❑ Summary
  - No overestimation of heat flux
- ❑ Conclusion
  - No effect in typical PWR SG geometry and modeling approach. Seems to be SMR-specific.
  - Is dividing secondary side of SG into a number of nodes (Control Volumes) always appropriate?

**Node 214**  
 $q(\text{POOL}) = 1.8\text{E}+005 \text{ W/m}^2$   
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$   
 $Q(\text{POOL}) = 5.8\text{E}+007 \text{ W}$   
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$   
 $Q(\text{POOL})/A = 1.8\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

**Node 211**  
 $q(\text{POOL}) = 3.0\text{E}+005 \text{ W/m}^2$   
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$   
 $Q(\text{POOL}) = 6.7\text{E}+007 \text{ W}$   
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$   
 $Q(\text{POOL})/A = 2.9\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

**Node 221**  
 $q(\text{POOL}) = 1.5\text{E}+005 \text{ W/m}^2$   
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$   
 $Q(\text{POOL}) = 4.7\text{E}+007 \text{ W}$   
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$   
 $Q(\text{POOL})/A = 1.5\text{E}+005 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$

**Node 224**  
 $q(\text{POOL}) = 9.8\text{E}+004 \text{ W/m}^2$   
 $q(\text{ATMS}) = 0.0\text{E}+000 \text{ W/m}^2$   
 $Q(\text{POOL}) = 2.2\text{E}+007 \text{ W}$   
 $Q(\text{ATMS}) = 0.0\text{E}+000 \text{ W}$   
 $Q(\text{POOL})/A = 9.7\text{E}+004 \text{ W/m}^2$   
 $Q(\text{ATMS})/A = 0.0\text{E}+000 \text{ W/m}^2$




# Sump Recirculation in SMR

## □ The SMR makes use of gravity-driven passive safety features for postulated accidents

- Heat removal through the four PRHR loops connected to the RPV
- Water injection in the RPV from the SITs
- Recirculation of water from the sump


## □ The sump recirculation is triggered by hydrostatic pressure in the CV

- After a LOCA, discharged coolant is condensed in the CV
- The pressure differential between the CV and the ICP opens the sump check valves
- The water is injected in the RPV downcomer through the ICP-to-RPV lines



# Check Valve Model

- ❑ The CF that triggers the check valve opening was based on the difference of upstream and downstream CV pressure, at first
  - The opening never occurred during the transient
  - The opening was experienced with other TH codes
- ❑ The reason was the lack of the contribution of the hydrostatic head in the CVs
- ❑ When passive systems governed by natural circulation are concerned the hydrostatic head plays a fundamental role
- ❑ Suggestion: why not consider the junction elevation directly in the valve model (e.g.: define junction pressures)?





# Core Flooding

## ❑ Safety injections provide the flooding of the core

- The decay heat removal is obtained by water evaporation
- The amount of liquid in the core is sensitive to the value of the bubble rise velocity in CVs


## ❑ Generally bubble rise velocity in a boiling RVP is ~ 1 m/s

- The MELCOR default value is 0.3 m/s
- The default value results in underestimation of the void fraction in the upper plenum
- The value was decreased to 0.1 m/s resulting in a better agreement with the other codes



# Core Flooding

- Sensitivity coefficient SC 4407 item 1: default  $v_{BUB} = 0.3$  m/s (left), modified  $v_{BUB} = 0.1$  m/s (right)



# Conclusions

## Issues and comments

### ❑ CHF Condition:

- SMR SG secondary side: fine CV nodalization can lead to CHF condition encountered in high void fraction volumes when high heat flux is involved
- A fine CV/HS nodalization is not envisaged in such situations

### ❑ Check Valve Model:

- Hydrostatic head plays a fundamental role in the actuation of passive safety systems that rely on natural convection or stored potential energy
- Control logic of check valves has to consider hydrostatic head for adequate modelling
- Can the FL package internally account for junction elevation in valves?

### ❑ Collapsed Water Level:

- The default value of the bubble rise velocity (0.3 m/s) in CVs results in a general underestimation of the CV void fraction
- A sensitivity calculation was performed with a modified value (0.1 m/s) which resulted in a better agreement in terms of RPV inventory, collapsed water level and void fraction



Thank you for your attention!  
Questions?

