SFP LOCA Analysis with MELCOR

NRG

Fabio Alcaro Marek M. Stempniewicz

EU DuC=N

6-7/04/2016

Outline

Introduction

- NRG applications of MELCOR
- □ NUGENIA+ AIR-SFP

Results of the Calculations

- SFP Loss of Cooling Accident
- > SFP LOCA

Modelling Issues

- SFP reactor type
- Zircaloy Oxidation

Conclusions



Introduction

Uses of MELCOR @ NRG:

Post-Fukushima SFP analyses

Spent Fuel Pool analyses in MELCOR (and other codes) in order to assess the coolability after a SFP LOCA scenario

Severe accident analysis for KERENA

- > (Part of) PSA Level 2 analysis
- Safety analyses for shutdown and power scenarios

□ HFR calculations for license renewal

- Severe accident analyses
- > PSA Level 2 analysis

□ Severe accident analyses for the KCB power plant

Safety analysis calculations

□ KCB power plant desktop simulator

- > Development of an interactive simulator of the Borssele NPP
- Dutch regulator personnel training

GKN Dodewaard Power Plant

- PSA Level 2 analysis
- Direct containment heating analysis (comparison of MELCOR vs CONTAIN)



Introduction

Desktop simulator

- TH codes: MELCOR, RELAP, MAAP and SPECTRA (NRG code)
- Visor: NRG visualization software compatible with the most widespread TH and SA codes



AIR-SFP: Description

- □ Analysis of severe accidents of SFP
- The SFP model is derived mainly from the Fukushima-Daiichi Unit 4 SFP
- □ Two scenarios are considered:
 - SFP Loss of Cooling Accident
 - SFP LOCA

	IF	3.60 kW
	1	1.12 kW
	2	0.55 kW
	4	0.40 kW
	5	0.30 kW
	8	0.24 kW
	9	0.23 kW
	10	0.22 kW
	12	0.21 kW
	14	0.20 kW
	16	0.19 kW
Support the support of the support of	24	0.16 kW



AIR-SFP: Model

□ SFP: 1 fuel & 1 bypass channel per ring + downcomer and pool top

- □ CORE: 3 rings × 13 axial levels (8 for active fuel)
- □ One radioisotope inventory representative of the hottest FAs





□ Sequence of events of the Scenario 1

□ Rack base plate failure occurs in all three radial rings

- > The fuel in the ring 3 does not produce power (fresh fuel)
- Power is radiated from neighbor ring 2

Event	Time [s]	Time [days]	Remarks
Gap release in rod group 1	1,275,350	14.8	
Gap release in rod group 2	1,378,310	16.0	
Gap release in rod group 3	1,396,770	16.2	
Core support structure has failed in cell ia= 2 ir= 1	1,443,720	16.7	Failure was by yielding at axial level 2 and radial ring 1
The lower head in segment 1 of ring 1 has failed from creep rupture	1,455,220	16.8	
Core support structure has failed in cell ia= 2 ir= 2	1,458,230	16.9	Failure was by yielding at axial level 2 and radial ring 2
The lower head in segment 2 of ring 2 has failed from thru-wall yielding	1,458,230	16.9	
Core support structure has failed in cell ia= 2 ir= 3	1,472,450	17.0	Failure was by yielding at axial level 2 and radial ring 3
The lower head in segment 3 of ring 3 has failed from thru-wall yielding	1,472,450	17.0	
End of calculation	2,592,000	30.0	Normal termination by end time reached.



□ Saturation conditions are reached after about 1 day

□ Fuel elements uncovery starts after about 10 days





Failure of the rack base plate occurs in all three radial rings
The event is highly dependent on the rack temperature







- Peak fuel temperature are reached as a consequence of oxidation breakaway
- □ The rate of hydrogen production increases in correspondence of cladding temperature increase



SFP LOCA

- □ Sequence of events of the Scenario 2
- Rack base plate failure occurs in radial rings 1 and 2 (corresponding to the powered FAs)
- During the LOCA the FAs are almost immediately exposed to air, while in the Scenario 1 they are exposed mainly to steam

Event	Time [s]	Time [days]	Remarks
Gap release in rod group 1	191,384	2.22	
Core support structure has failed in cell $ia=2$ ir= 1	212,964	2.46	Failure was by yielding at axial level 2 and radial ring 1
The lower head in segment 1 of ring 1 has failed from thru-wall yielding	212,965	2.46	
Gap release in rod group 2	227,904	2.64	
Core support structure has failed in cell $ia=2$ ir= 2	305,385	3.53	Failure was by yielding at axial level 2 and radial ring 2
End of calculation	432,000	5.00	Normal termination by end time reached.





- □ Saturation conditions are reached during the blowdown phase
- □ Fuel elements uncovery starts after about 2.5 days



SFP LOCA

- □ Failure of the rack base plate occurs in radial rings 1 and 2 (only powered FAs)
- □ The event is highly dependent on the rack temperature



5

SFP LOCA

7/04/16

- Peak fuel temperature are reached as a consequence of oxidation breakaway
- □ The rate of hydrogen production increases in correspondence of cladding temperature increase



13

Modelling Issues SFP Reactor Type

□ Rack component model:

- SFP-BWR: new component type 'rack' (mass in COR_KRK, surface in COR_RSA cards)
- BWR: generic NS SUPPORT component

□ Different treatment of the loads on the structures (other differences?)

SFP-BWR	BWR
11 NS SUPPORT FIXED FIXED FIXED	11 NS SUPPORT BELOW BELOW BELOW
METAL STEEL STEEL STEEL	METAL STEEL STEEL STEEL
DRMIN(M) 1.00E-04 1.00E-04 1.00E-04	DRMIN(M) 1.00E-04 1.00E-04 1.00E-04
TMAX (K) 1700.00 1700.00 1700.00	TMAX (K) 1700.00 1700.00 1700.00
10 NS SUPPORT FIXED FIXED FIXED	10 NS SUPPORT BELOW BELOW BELOW
METAL STEEL STEEL STEEL	METAL STEEL STEEL STEEL
DRMIN(M) 1.00E-04 1.00E-04 1.00E-04	DRMIN(M) 1.00E-04 1.00E-04 1.00E-04
TMAX (K) 1700.00 1700.00 1700.00	TMAX (K) 1700.00 1700.00 1700.00
9 NS SUPPORT FIXED FIXED FIXED	9 NS SUPPORT BELOW BELOW BELOW
(etc.)	(etc.)
EDIT OF CORE COMPONENT MASSES (KG)	EDIT OF CORE COMPONENT MASSES (KG)
()	()
*** LOAD (kg) CARRIED BY SUP-STR = 1.5696E+05	*** LOAD (kg) CARRIED BY SUP-STR = 1.8738E+05
*** STRESS IN SUP-STR = 1.2647E+07	*** STRESS IN SUP-STR = 1.5098E+07



□ MELCOR lifetime of Zircaloy:

 $\log_{10} \tau = 42.038 - 12.528 \cdot \log_{10} T$

□ Life function for breakaway:

$$LF = \int_0^t \frac{t'}{\tau(T)} dt' = 1$$
$$t = \sqrt{2\tau}, \quad T = const$$

- LF is dimensional [s] (?)
- A test calculation (T = 963 K) results in $t \approx 40,000$ s (in agreement with the Figure), while from the formula results $t \approx 283$ s
- Suggested modification of User's Guide (COR_OXB):

$$LF = \int_0^t \frac{dt'}{\tau(T)} = 1$$

t = \tau, T = const

1000 Best-Estimate Curve Fit PLOX - 2.365*SEv – PLOX + 2.365*SEV ANL Data 100 Breakaway Timing [hr] $P_{LOX} = -12.528 \cdot \log_{10} T + 42.038$ $SE_{y} = 0.2645$ 10 1 0.1 700 800 900 1000 1100 1200 1300

Temperature [K]

R. Gauntt et al., Fukushima Daiichi Accident Study, SAND2012-6173

The zircaloy oxidation section (2.5.1) of the COR package reference manual has not been modified since version 1.8.6 (September 2005)



- □ From MELCOR version 2.1 (build 3166) the default values of the sensitivity coefficients for zircaloy-air oxidation have been changed
- No information is given in the Reference Manual regarding the new correlation!



- From MELCOR version 2.1 (build 6840) a new model option for zircaloy oxidation is available (COR_OX)
- No description is given in the Reference Manual regarding the new correlations!

! PSI	Oxidation breakaway model				
!	active	H20	Air	02	breakaway
cor_ox	1	0	0	0	0

(1) STEAM

Steam oxidation model

0 - Catchart-Pawel/Urbanic-Heidrick;

(2) AIR

Air Oxidation Model

0 - Hofmann-Birchley;

OXYGEN

Oxygen oxidation model

0 – Uetsuka-Hofman;

NOBRK

7/04/16

Breakaway Switch

0 - enable in steam and air (recommended);



Conclusions

- MELCOR has been used to simulate severe accidents evolution of a generic SFP within the framework of the NUGENIA+ project
- SFP applications of MELCOR lack of full validation (SNL analysis on Fukushima SFP4 only covers the boil-off phase)
- □ The MELCOR 2.1 reactor types SFP-BWR and SFP-PWR includes a few enhancements towards SFP modelling application:
 - The new rack component is not considered in the load calculation of the support plate, which is consistent for SFP applications
 - There are not evidences that the rack component and the standard NS structures are treated differently in the COR package
- Some deficiencies/inconsistencies in the MELCOR 2.1 Reference and User's Guide manuals have been found in regards of the zircaloy oxidation model
 - In MELCOR version from (at least) 2.1.3166 the coefficients of the oxidized metal rate correlation are different between the Reference Manual and User's Guide
 - In MELCOR version 2.1.6843 the PSI oxidation model has been introduced but no information is given about the correlations adopted by the code



Thank you for your attention! Questions?

NZG