

ÚJV Řež, a.s.

Using MELCOR 2.1 as a thermal-hydraulics analysis code (GFR)

Petr Vácha (petr.vacha@ujv.cz)

Nuclear Research Institute Rez

9th EMUG, 6th and 7th of April 2017, Madrid, Spain




- **What is ALLEGRO**
- **Code-to-code TH benchmark**
- **Preliminary results**
- **Future outlook**




- **ALLEGRO concept:**
 - Reactor unit size: **75 MWt**
 - Core power density: **100 MWt/m³**
 - Coolant: **He**
 - Nominal pressure: **7 MPa**
 - Fuel forms: **MOX pin-type** (starting core)
Ceramic pin-type (refractory core)
 - Core outlet temperature: **530°C** (starting)
850°C (refractory)



ALLEGRO 75 MWt



ALLEGRO - MOX Core



-  Experiment
-  MOX
-  Control
-  Shutdown





■ Purpose

- unifying (and improving) input decks, comparing results

■ Codes

- RELAP5 (VUJE),
- CATHARE2 (MTA-EK, NCBJ, UJV),
- MELCOR 2.1 (UJV)

■ Schedule

- 2016 – preparation of Database and Benchmark specs.
- 03/2017 – Steady state qualification
- 06/2017 – Transient calculations comparison

■ Why MELCOR (SA code) in TH bench?



- **2 Transients selected for the transient calculation comparison**
 - LOCA on main cold duct
 - SBO

- **Compared results**
 - Over 60 compared values for the steady state
 - Over 40 compared values for the transients (Temperatures, pressures, mass flow rates, etc.)

ALLEGRO TH Benchmark (3/3)



Property	Reference value	MELCOR value	Acceptable error (%)	MELCOR error (%)
Core inlet temperature (°C)	260.0	259.1	0.5	0.35
Core outlet temperature (°C)	516.0	513.88	0.5	0.41
Core inlet pressure (MPa)	7.0	6.99	0.1 (?)	0.13
Core mass flow rate (kg/s)	56.45	56.79	2.0	0.6
Core pressure drop (kPa)	84.0	84.8	10.0	0.95
MHX pressure drop (kPa)	20.0	11.4	10.0	43.0 (!)

- **MELCOR related**

- Lack of details in some areas – temperature profiles inside cladding/fuel

- **Modeling related**

- Hot channel definition (power distribution)
- Core modelling

- **Possibly my own lack of skill**

- HX model – works well in the steady state, oscillations and instability in transients. Any experience?
- Homologous pump model – any experience?

Preliminary comparison CATHARE-MELCOR



- **Transient: LOCA 1" on one cold leg + SBO, 1 N2 accumulator available, 2 DHR loops available (+ 2" and 3" LOCA)**
- **Synchronized initial and boundary conditions:**
 - Nominal conditions in PC (Pressure in lower/upper plenum, core mass flow rate, power, blowers performance, conditions in GV)
 - Fission and decay power over time
 - Size of the N2 accumulator, initial pressure and temperature of N2 in it, conditions for opening the accumulator (PC pressure below 3 MPa)
 - Initial mass flow rate of N2 from the accumulator
 - Rate of PC depressurization (for 1" breach only)
 - Timing of main and DHR valves closure/opening

Major differences between the models




- Heat capacity of the core (absence of non-fuel SAs, adiabatic hot channel)
- Differences in DHR system (different boundary conditions and volumes)
- General differences in volumes and areas


Results (1/4) – 1" LOCA 50 MW




1" LOCA + SBO, 50 MWth, 1 N2 ACCU: Max. cladding temperature



1" LOCA + SBO, 50 MWth, 1 N2 ACCU: Upper plenum pressure




1" LOCA + SBO, 50 MWth, 1 N2 ACCU: ACCU Flow rate to PC




Results (2/4) – 1" LOCA 75 MW



1" LOCA + SBO, 75 MWth, 1 N2 ACCU: Max. cladding temperature




1" LOCA + SBO, 75 MWth, 1 N2 ACCU: Upper Plenum Pressure




Results (3/4) – 2" LOCA 50 MW



2" LOCA + SBO, 50 MWth, 1 N2 ACCU: Max. cladding temperature




2" LOCA + SBO, 50 MWth, 1 N2 ACCU: Upper Plenum Pressure




Results (4/4) – 3" LOCA 50 MW



3" LOCA + SBO, 50 MWth, 1 N2 ACCU: Max. cladding temperature



3" LOCA + SBO, 50 MWth, 1 N2 ACCU: Upper Plenum Pressure



■ 2018-2020 Code-to-experiment benchmark (TH)

- S-ALLEGRO and STU loops
- The loops will contribute to the reactor development, too

■ SA assesment

- All the already calculated results need to be evaluated and put into one document (2017-2018)
- Unprotected transients calculations (point kinetics model applicable to fast reactors?)
- Crucial tasks
 - complete conceptual design of Guard Vessel internals
 - core catcher concept (2016 – 2018)

■ GFR oriented SA research

- Big safety-oriented research project (ALFA) rejected by the EU -> delay
- Several new projects (national and international) under evaluation/in the preparation phase

Conclusions



- Detailed ALLEGRO TH benchmark has been prepared, comparing 3 codes and 5 users
- Qualitatively, MELCOR is capable to calculate the transients in ALLEGRO in the same way as CATHARE
- Quantitatively, differences in results are in in correspondence with the differences in models.
- Comparison of critical flow models in LOCA breaches should be done