


Results of TH benchmark on GFR

Petr Vácha (petr.vacha@ujv.cz)
Nuclear Research Institute Rez

10th EMUG, 25th - 27th April 2018, Zagreb, Croatia




Contents

- **What is ALLEGRO**
- **Code-to-code TH benchmark**
- **Problems I have encountered**

GFR ALLEGRO - specifications


- **ALLEGRO concept:**
 - Reactor unit size: **75 MWt**
 - Core power density: **100 MWt/m³**
 - Coolant: **He**
 - Nominal pressure: **7 MPa**
 - Fuel forms:
MOX pin-type (starting core)
Ceramic pin-type (refractory core)
 - Core outlet temperature: **530°C (starting)**
850°C (refractory)

ALLEGRO 75 MWt (2009)



ALLEGRO 75 MW (2018)

- **ALLEGRO 2018 concept:**
 - 3 main cooling loops (120°)
 - 3 DHR system loops (120°C)
 - Emergency coolant injection system
 - New design of the DHR system HX
 - Improved safety – all protected transients within DBA





ALLEGRO TH code-to-code Benchmark (1/3)

■ Purpose


- Comparison of codes and users capabilities, unifying (and improving) input decks,

Codes

- RELAP3D (VUJE),
- CATHARE2 (MTA-EK, VUJE), MELCOR 2.2 (UJV)


■ Status

- First evaluation done, second round of the benchmark underway



ALLEGRO TH Benchmark (2/3)


- **2 Transients selected for the transient calculation comparison**
 - LOCA on main cold duct
 - SBO
- **Compared results**
 - Over 60 compared values for the steady state
 - Over 40 compared values for the transients (Temperatures, pressures, mass flow rates, etc.)



ALLEGRO TH Benchmark (3/3) – steady state

Property	Refference value	MELCOR value	Acceptable error (%)	MELCOR error (%)
Core inlet temperature (°C)	260.0	259.1	0.5	0.35
Core outlet temperature (°C)	516.0	513.88	0.5	0.41
Core inlet pressure (MPa)	7.0	6.99	0.1	0.13
Core mass flow rate (kg/s)	56.45	56.79	2.0	0.6
Core pressure drop (kPa)	84.0	84.8	10.0	0.95
MHX pressure drop (kPa)	20.0	15.94	10.0	19.9
MHX area water side (m2)	121.02	134.56	10.0	11,19

Core nodalization in MELCOR (CVH- FL)



Core nodalization in MELCOR (COR)

Channel								Bypass							
ring level	1	2	3	4	5	6	7	ring level	1	2	3	4	5	6	7
25	CVH_007	CVH_009	CVH_009	CVH_009	CVH_005	CVH_005	CVH_100	25	-	-	-	-	-	-	-
24	CVH_007	CVH_009	CVH_009	CVH_009	CVH_005	CVH_005	CVH_100	24	-	-	-	-	-	-	-
23	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	23	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
22	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	22	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
21	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	21	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
20	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	20	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
19	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	19	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
18	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	18	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
17	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	17	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
16	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	16	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
15	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	15	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
14	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	14	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
13	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	13	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
12	CVH_006	CVH_008	CVH_006	CVH_008	CVH_005	CVH_005	CVH_100	12	CVH_080	CVH_080	CVH_080	CVH_080	-	-	-
11	CVH_003	CVH_004	CVH_004	CVH_004	CVH_005	CVH_005	CVH_100	11	-	-	-	-	-	-	-
10	CVH_003	CVH_004	CVH_004	CVH_004	CVH_005	CVH_005	CVH_100	10	-	-	-	-	-	-	-
9	CVH_002	CVH_002	CVH_002	CVH_002	CVH_002	CVH_002	CVH_100	9	-	-	-	-	-	-	-
8	CVH_002	CVH_002	CVH_002	CVH_002	CVH_002	CVH_002	CVH_100	8	-	-	-	-	-	-	-
7	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001	CVH_100	7	-	-	-	-	-	-	-
6	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001	CVH_100	6	-	-	-	-	-	-	-
5	CVH_001	5	-	-	-	-	-	-	-						
4	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001		4	-	-	-	-	-	-	-
3	CVH_001	CVH_001	CVH_001	CVH_001	CVH_001			3	-	-	-	-	-	-	-
2	CVH_001	CVH_001	CVH_001	CVH_001				2	-	-	-	-	-	-	-
1	CVH_001	CVH_001	CVH_001					1	-	-	-	-	-	-	-

Legend:

- Downcomer
- Lower head
- Support plate
- Shielding
- Reflector
- Fuel






Results of LOCA 75mm

- Core power
- Core mass flowrate
- Maximum cladding temperature
- MHX feedwater inlet temperature
- Break mass flow rate






LOCA 75mm results – core power






LOCA 75mm results – core mass flowrate






LOCA 75mm results – maximum cladding T






LOCA 75mm results – MHX feedwater inlet T





LOCA 75mm results – Break mass flow rate






Results of SBO


- Core power
- Core mass flowrate
- Maximum cladding temperature
- Core inlet pressure
- DHR HX flowrate (He side)




SBO results – core power




SBO results – core mass flowrate




SBO results – maximum cladding T



SBO results – Core inlet pressure



SBO results – DHR HX flowrate (He side)





Issues – point kinetics model

```
COR_PKM01 0.00    7.029E+07
COR_PKM02  'CF_10' 'CF_11' !External reactivity from cntrl. rods and neutron source
COR_PKM03  3
                           1  RDOP      2  ! fuel density
                           2  RFUF      2  ! fuel temperature
                           3  RMODF     1  ! coolant temperature
COR_TAVG   2
                           1          13-22  1-3      MOD   Zr
                           2          13-22  1-3      FU    UO2
```

ERROR: Error on card: COR_PKM02

the Reactivity name CF_10 IS NOT FOUND

ERROR: Error on card: COR_PKM02

the Reactivity name CF_11 IS NOT FOUND

ERROR: Error in table: COR_PKM03 Row: 1

the Reactivity name CF_11 IS NOT FOUND

ERROR: RECORD Error(s) occur in the first pass of MELGEN inputs for COR Package IS REQUIRED

3 ERRORS WERE DETECTED DURING PROCESSING OF COR INPUT DATA

Conclusions

- Detailed ALLEGRO TH benchmark has been prepared, comparing 3 codes and 5 users
- Qualitatively, MELCOR is capable to calculate the transients in ALLEGRO in the same way as CATHARE and RELAP
- Quantitatively, most of the differences in results are in correspondence with the differences in the codes.
- Comparison of critical flow models in LOCA breaches should be done
- „Round 2“ of the benchmark is foreseen after full evaluation of the results